



Product Service

Attestation of Conformity

No. N8A 084752 0035 Rev. 00

Holder of Certificate: **München Energieprodukte GmbH**
Stethaimerstr. 32-34
84034 Landshut
GERMANY

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062117101-00

Date, 2021-10-14

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 084752 0035 Rev. 00

Model(s):

MSMDxxxM6-72,xxx=415 to 460 in step of 5
MSMDxxxM6-60,xxx=345 to 380 in step of 5
MSMDxxxM3-72,xxx= 395 to 420 in step of 5
MSMDxxxM3-60,xxx= 330 to 350 in step of 5
MSMDxxxM6-78,xxx= 450 to 495 in step of 5
MSMDxxxM6-66,xxx= 380 to 420 in step of 5
MSMDxxxM6-HD72NBG,xxx=440 to 465 in step of 5
MSMDxxxM6-HD66NBG,xxx=405 to 425 in step of 5
MSMDxxxM6-HD60NBG,xxx=370 to 385 in step of 5
MSMDxxxM6-HD54NBG,xxx=330 to 345 in step of 5
MSMDxxxM12-66,xxx=650 to 670 ,in step of 5
MSMDxxxM12-72,xxx=590 to 605,in step of 5
MSMDxxxM10-54,xxx=390 to 410 in step of 5
MSMDxxxM6-54,xxx=315 to 340 in step of 5
MSMDxxxM10-78,xxx=560 to 595 in step of 5
MSMDxxxM10-72,xxx=530 to 550 in step of 5
MSMDxxxM10-66,xxx=480 to 500 in step of 5
MSMDxxxM10-60,xxx=435 to 455 in step of 5
MSMDxxxM12-50,xxx=545 to 555,in step of 5
MSMDxxxM12-60,xxx=495 to 505,in step of 5
xxx is standing for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06